



MAXWELL DIESELS & ELECTRICALS PVT. LTD.

No. 4, 9th Main, Near Venkateshwara Temple, Vasanthnagar, Bengaluru - 560 052.

Ph. : 080-40929666, Mob. : 9900129097, 9845010557

E-mail : mdspl@maxwelldiesel.com Website : www.maxwelldiesel.com

FIELD SERVICE REPORT

No.

Date : 16/12/2022

Customers Name & Address

M/s. Sindhi College
Hebbal Kempapura
Bengaluru

Ph. No.

Name & Designation of Person

Mr. Manjunath

Customer's Complaint

General check up under fine for -

Engine (1) Make : Commines
(2) Type : GLTA8-3-e17-1
(3) Sl. No.: 25752013

Alternator (1) Make : Stamford
(2) Type : UC2744FI
(3) KVA : 160 kVA
(4) Sl. No.: 85110749

Description of Work Done : Inspection above maintained
Diesel found checked the Engine oil-
level, checked the Battery Distilled
-water level, checked the Radiator coolant
-water level, cleaned the Diesel
checked the Radiator hose pipe &
fan belt - finally other general check
up was done. Started the Diesel
found all

Performance Checkup / Range

Total No. of Hrs. Run	Healthy	Actuals	
R P M	1500	1500	
Oil Pressure	3to6.5kg	6.5to	
Battery Volt	12/24v	24v	
Water Temp	60/90° C	60°	
KWH Reading		-	
Volts	Hz	Amps	
	R	Y	B
Av	51	-	-

Note :

Spares Required

Spares Supplied

Name of Service Engineers

C. Lokesh, Rama Krishna
Signature
Date 16/12/2022

Customer's Remarks

oil servicing to be next
-servicing

SERVICE IS OUR MOTTO & PRIDE

Customer Signature

PRINCIPAL
SINDHI COLLEGE
#33/2B Kempapura, Hebbal,
Bengaluru - 560 024



DECCAN ELEVATORS

Installation, Modernization & Maintenance of Elevators & Escalators

"FIFTH AVENUE" Shopping Arcade,
206, 2nd Floor,
182-184, Brigade Road,
Bengaluru - 560 001.
Mob. : 90086 51218 / 84970 45485
Email : deccanelevator@gmail.com

INVOICE

The President, M/s. Sindhi Seva Samithi, Kumara Krupa Road, Bangalore.		Inv. No. DE/163/2022-23		Dated : 02.01.2023	
		D.C.No.		Dated :	
		Work Order No.		Dated :	
		PAN :		AAGFD687IN	
Cust GST No.		L.R. No.		Dated :	
Sl. No.	DESCRIPTION	HSN CODE	QTY. (Nos.)	UNIT RATE (in Rs.)	VALUE (in Rs.)
1	Periodical Maintenance for Passenger Elevator at Sindhi College, Hebbal, Bangalore as per renewal AMC dated 27.12.2022 for the Period from January 2023 to December 2023	00440245	1 No.	25,400 (Per Annum)	25,400
				TOTAL	25,400
				IGST 18%	-
				CGST 9%	2,286
				SGST 9%	2,286
				GRAND TOTAL	29,972
In words: Twenty Nine Thousand Nine Hundred Seventy Two only			For DECCAN ELEVATORS,		
Prepared by:		Checked by :		Authorised Signatory.	

E.& O.E.

Handwritten signature
PRINCIPAL
SINDHI COLLEGE
#33/2B Kempapura, Hebbal,
Bengaluru - 560 024



DECCAN ELEVATORS

Installation, Modernization & Maintenance of Elevators & Escalators

"FIFTH AVENUE" Shopping Arcade,
206, 2nd Floor,
182-184, Brigade Road,
Bengaluru - 560 001.
Mob. : 90086 51218 / 84970 45485
Email : deccanelevator@gmail.com



AMC RENEWAL

Ref: DE/R/434/22-23

December 27, 2022

**THE PRESIDENT,
M/s. SINDHI SEVA SAMITHI,
KUMARA KRUPA ROAD,
BANGALORE.**

Dear Sir / Madam,

Sub: Renewal of Annual Maintenance Contract Effective 01.01.2023

Ref: Our AMC dated 9th January 2018 For Maintenance of 1 No. Passenger Elevator at the above addressed premises

We take this opportunity to express our sincere thanks to you for awarding us the Maintenance Contract of the Elevator installed at your building. We are eager to serve you to the fullest satisfaction with regard to maintenance of elevator. If there is anything more we can add to our service, please do inform us to enable us improve our customer service. Also, if you feel that we need to provide any value additions to the elevator to suit your requirement, please do not hesitate to call us on any of the numbers mentioned here above. Your feedback is very valuable to us and we will be happy to have an opportunity to serve you better.

While looking forward to a long & fruitful relationship ahead, we would like to bring to your kind notice that the above referred AMC for maintenance of the elevator expires on **31.12.2022.**

Hence, we propose to furnish Renewal of AMC for 1 No. PASSENGER ELEVATOR, located at the above premises for a subsequent period of 12 months.

TERMS OF AGREEMENT :

1. The subsequent AMC period is for 12 months commencing from **01.01.2023 to 31.12.2023.**
2. AMC charges for this period shall be **Rs.26,670/-** (Rupees Twenty Six Thousand Six Hundred Seventy) only.

**PRINCIPAL
SINDHI COLLEGE
#33/2B Kempapura, Hebbal,**



DECCAN ELEVATORS

-2-

3. GST @ 18% or as applicable will be levied extra on the AMC charges.
4. AMC charges along with GST is payable yearly in advance. Invoice is attached herewith for necessary action.
5. All other terms and conditions of existing contract remains unchanged.

Kindly affix your signature with date and please return the duplicate copy of this renewal of contract for our records along with payment.

ACCEPTED BY THE CUSTOMER,

Aashish Amralak
.....
CLIENT'S SIGNATURE WITH SEAL

NAME :

TITLE :

DATE:

For DECCAN ELEVATORS,

T.S. Chandrasekhar
.....

.....
SIGNATURE OF AUTHORISED OFFICIAL,

NAME: *S.SHIVARAM*
.....

DESIGNATION: *Managing Partner*
.....

DATE: *27/12/2022*
.....

Acir
PRINCIPAL
SINDHI COLLEGE
#33/2B Kempapura, Hebbal,
Bengaluru - 560 024

SINCERE

*

DEDICATED

*

SERVICE



MAXWELL DIESELS & ELECTRICALS PVT. LTD.

No. 4, 9th Main, Near Venkateshwara Temple, Vasanthnagar, Bengaluru - 560 052.

Ph. : 080-40929666, Mob. : 9900129097, 9845010557

E-mail : mdspl@maxwelldiesel.com Website : www.maxwelldiesel.com

FIELD SERVICE REPORT

No.

Date : 16/12/2022

Customers Name & Address

M/s. Sindi College
Hebbal Kempapura
Bengaluru

Ph. No.

Name & Designation of Person

MR. Manjunath

Customer's Complaint

General check up under Amc for 200kVA
KEI

Engine

(1) Make : KOEL
(2) Type : GSL1500TA E12
(3) Sl. No. : FG.9626/1620004

Alternator

(1) Make : ~~FS3M2 15L 200839~~
(2) Type : KEI 250 M2
(3) KVA : 200
(4) Sl. No. : FS3M2 15L 200839

Description of Work Done :

Inspection above maintained Diesel set found checked The Engine oil level, checked The Radiator Coolant level, & water level, checked The Radiator coolant level. checked The Radiator hose pipe & fan belt cleaned The Air filter, & Diesel finally other general check up was done. Started The Diesel set found OK

Performance Checkup / Range

Total No. of Hrs. Run	Healthy	Actuals	
R P M	1500	1500	
Oil Pressure	3to6.5kg	6.5kg	
Battery Volt	12/24v	24v	
Water Temp	60/90° C	60° C	
KWH Reading	—		
Volts	Amps		
	R	Y	B
100	50	—	—

Note :

Spares Required

Spares Supplied

Name of Service Engineers

C. Lokesh, Rama Krishna
Signature
Date 16/12/2022

Customer's Remarks

oil servicing to be done Next
- Servicing

SERVICE IS OUR MOTTO & PRIDE

Customer Signature

PRINCIPAL
SINDHI COLLEGE
#33/2B Kempapura, Hebbal,
Bengaluru - 560 024